

WO #02-60456-0 AND ALL ASSOCIATED SUBS

MO.NO.....	Description.....	Crew No
02-60456-53	RUN TEMP POWER FOR ADDITIONAL BOILER CONTRACTOR WORK BY TEI AT THE AIR HEATERS AND BURNERS. THERE WILL BE AT LEAST THREE TRAILERS, THEY WILL NEED 240V FEEDERS TO EACH, ALSO PHONES WILL BE PROVIDED ON A SEPERATE WORK ORDER.	63
<u>02-60456-54</u>	UNIT 2 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR PHIL HAILES)	81
02-60456-55	UNIT 2 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR PHIL HAILES) FOR WINDBOX DUCT INSTALLATION	81
02-60456-56	UNIT 2 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR PHIL HAILES) FOR HVAC DUCT RELOCATION	81
02-60456-57	PRE-OUTAGE AND OUTAGE WORK FOR OVERFIRE AIR SYSTEM, IGS02-14. WORK ON CCS SYSTEM TO INSTALL AND WIRE NEW CARDS, PROGRAM AND TEST. LINEUP OF EACH JORDAN AMPLIFIER ON OVERFIRE AIR DAMPERS.	192
02-60456-58	FABRICATE PIPE WITH CAP AND HANDLE FOR INSTALLATION ON BOILER WALL DURING OUTAGE.	57
02-60456-59	Sub wo to 02-60456, U2 OFA Cost Tracker for IPSC purchased Materials.	88
02-60456-60	Sub wo to 02-60456. U2 OFA "Cost Tracker" I&E Contract Labor.	88
02-60456-61	Sub wo to 02-60456. U2 OFA, Ken Nielson "Cost Tracker" for I&E Contractor Materials.	88
<u>02-60456-62</u>	UNIT 1 "OVER-FIRE CONTRACTOR COST TRACKER" (FOR BRET KENT) FOR SAFEWAY SCAFFOLD	81
02-60456-63	REMOVE AIR LINES FROM RAMS AND LOCATE ABOVE THE BURNERS SO THEY ARE NOT DAMAGED.	192
02-60456-64	Complete removal of Isoc. wiring from UCM 13 per drawings and instructions from Ken Nielson or Bill Morgan.	192
02-60456-65	Install/Program the controls blocks and logic in U2 CCS for the OFA system. See Ken Nielson or Bill Morgan for package and questions.	192
02-60456-66	Wring out OFA controls wiring, complete drive amplifier line-up, and work with Ken Nielson or Phil Hailes on OFA Damper line-up with drives.	192
02-60456-67	Calibrate magnahelix D/P meter for OFA system. See Ken Nielson for instructions.	192